

Control panel

The control system is used to achieve controlled dehumidification in crawl spaces. Control, regulation and monitoring of the crawl space installation occurs via a hygrostat connected to the dehumidifier in the space and a control panel in the living area.

The crawlspace dehumidifier is controlled by a hygrostat that is located in the crawl space where the conditions are considered suitable or particularly critical. For additional monitoring a control panel (indicator box) is positioned in the living area where the indicator lamps, for example, display if the relative humidity in the crawl space is OK or too high, if the installation is functioning or if there has been any interruptions to operation.

System solutions

Crawl space dehumidifier CTR 500TT



Part no. 10200

Hygrostat HR1-5

Hygrostat HR1-5 fits all Corroventa's normal dryers. Used during drying when the conditions are considered sensitive or particularly critical. Connection cable 5 m. Dehumidification 10-90 % RH.



Part no. 01100